

**Department of Early Education and Care  
HEALTH INSPECTION REPORT**

This is to certify that Catchins School  
(Name of Facility)

located at 52 Old Bay Road, Belchertown MA 01007  
(Street) (City) (Zip)

was inspected on 9/21/2023 by Andrea Crete  
(date) (Name of Inspector)

of Quabbin Health District & Belchertown Board of Health  
(Inspection Board, Agency or Department)

The above facility complies with Chapter 11 of the State Sanitary Code and other regulations pertinent to the following areas:

- |  |   |  |  |
|--|---|--|--|
| Kitchen Facilities                     | Yes <input checked="" type="checkbox"/> | No <input type="checkbox"/>            |  |
| Food Storage and Preparation           | Yes <input checked="" type="checkbox"/> | No <input type="checkbox"/>            |  |
| Water Supply                           | Yes <input checked="" type="checkbox"/> | No <input type="checkbox"/>            |  |
| Hot Water Temperature                  | Yes <input type="checkbox"/>            | No <input checked="" type="checkbox"/> | = unable to verify hot water temperature due to level of propane.        |
| Bathroom Areas                         | Yes <input checked="" type="checkbox"/> | No <input type="checkbox"/>            |  |
| Sewage System                          | Yes <input checked="" type="checkbox"/> | No <input type="checkbox"/>            |  |
| Lighting and Electrical Operations     | Yes <input type="checkbox"/>            | No <input type="checkbox"/>            |  |
| Heat                                   | Yes <input checked="" type="checkbox"/> | No <input type="checkbox"/>            |  |
| Ventilation                            | Yes <input type="checkbox"/>            | No <input checked="" type="checkbox"/> | - Bathroom vents not observed to be working.                             |
| Smoke Detectors                        | Yes <input checked="" type="checkbox"/> | No <input type="checkbox"/>            |  |
| Exits                                  | Yes <input checked="" type="checkbox"/> | No <input type="checkbox"/>            |  |
| Asbestos                               | Yes <input checked="" type="checkbox"/> | No <input type="checkbox"/>            |  |
| Garbage and Rubbish Disposal & Storage | Yes <input checked="" type="checkbox"/> | No <input type="checkbox"/>            |  |
| Control of Insects, Rodents & Skunks   | Yes <input type="checkbox"/>            | No <input checked="" type="checkbox"/> | - weather stripping<br>not seen @ bottom<br>exit doors, need to<br>seal. |
| Approved:                              | Yes <input type="checkbox"/>            | No <input type="checkbox"/>            | *Conditionally <input checked="" type="checkbox"/>                       |

re-inspection date 9/25/23 @ 9 AM

Recommendations:

- ① Could not verify ventilation system was working in the Bathrooms. Will need to come back to verify once this is looked into. There was no indication vents were on when light switch was turned on.
- ② Some light is observed coming through bottom of exit doors. Weather stripping will need to be adjusted or more added to completely seal any gaps allowing light.
- ③ Hot water temperature needs to be verified. Unable to do this upon inspection due to pressure levels.

*Andrea Lute*

*9/21/2023*

Signed (Inspector or Representative of Inspecting Authority)

**\*Conditional approval may be given only when, in the opinion of the inspecting authority, children's health would not be endangered in the facility prior to the correction of noted non-compliance items. Conditional approval will satisfy provisional licensing requirements, but certification must be obtained before a regular license can be issued.**